

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190930-R39790  
**Report Reference** R39790-20190917  
**Issue Date** 2019-SEPTEMBER-30

**Issued to:** AGB Alban Giacomo Spa  
Via A. De Gasperi 75  
36060 Romano d'Ezzelino VI ITALY

**This certificate confirms that  
representative samples of** DOOR HINGES  
See Addendum Page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL10C - STANDARD FOR POSITIVE PRESSURE FIRE  
TESTS OF DOOR ASSEMBLIES  
UL10B - STANDARD FOR FIRE TESTS OF DOOR  
ASSEMBLIES  
CAN/ULC-S104 - FIRE TESTS OF DOOR ASSEMBLIES

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190930-R39790  
**Report Reference** R39790-20190917  
**Issue Date** 2019-SEPTEMBER-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

**Models/Products:**

USL, CNL Models Type Eclipse 3.0, Eclipse 3.1, Eclipse 3.2, Eclipse 3.2 HD, Eclipse 3.3, Eclipse 3.4, Eclipse 3.4 HD and Eclipse 3.5 for use on swinging type fire doors of types wood / composite type rated up to and including 1 hour with a minimum thickness of 70 mm, incorporating active bolts and studs, for doors (leaf) limited to 952 mm wide x 2421 mm high.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

