

Trade Mark	-					
Model	100 Colibri					
Specific energy consumption (SEC), kWh/(m ² .A)	Cold		Average		Warm	
	-28,3	B	-11,9	E	-2,5	F
Type of ventilation unit	Unidirectional residential ventilation unit					
Type of drive installed	Single speed					
Type of heat recovery system	None					
Thermal efficiency of heat recovery, %	Non applicable					
Maximum flow rate, m ³ /h	90					
Electric power input, W	15					
Sound power level, dB(A)	55					
Reference flow rate, m ³ /s	0,018					
Reference pressure difference, Pa	Not applicable					
Specific power input (SPI), W/(m ³ /h)	0,167					
Control typology	Local demand control					
Maximum internal leakage rates, %	Not applicable					
Maximum external leakage rates, %	2,7%					
Airflow sensitivity at +20 Pa and -20 Pa	0,15					
The indoor/outdoor air tightness, m ³ /h	1					
Internet address	http://www.erp-equation.com/aerators/					
The annual electricity consumption (AEC), kWh electricity/a	Cold		Average		Warm	
	209		209		209	
The annual heating saved (AHS), kWh primary energy/a	Cold		Average		Warm	
	3355		1715		776	