

Certificate of constancy of performance



according to Regulation (EU) No. 305/2011

Certificate No.: 1008-CPR-MC 69266398 0001

Report No.: HU22U968 001

Applicant: WKBM
5 Rue des Pyrénées, 91090 LISSES, France

Manufacturer: WKBM
5 Rue des Pyrénées, 91090 LISSES, France

Manufacturing plant: Zhejiang HuaXiao Technology Co.,Ltd.
1-3/F, Building A2 ,No. 28 Dongqiao Road, Dongzhou
Street, Fuyang District, Hangzhou, Zhejiang, China

Product: Smoke alarm

Identification: DETC40IR, DETC50RF
Intended use: Fire safety
FPC Report No.: HU22JUS2 001
Test report: CN222T6K 001, CN222T6K 002, CN222T6K 003

**System of assessment
and verification:** 1

Tested according to: EN 14604:2005; EN 14604:2005/AC:2008

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performance described in Annex ZA of the above standard(s) under above system are applied and the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 2022-11-08 and it will remain valid until the test methods and/or factory production control requirements included in the standard, used to assess the performance of the declared characteristics, and the product, and the manufacturing conditions in the plant are unchanged. The manufacturing plant and factory production control system of the manufacturer is supervised regularly by the Certification Body.

Certification Body

Date of issue:

Budapest, 2022-11-08

A handwritten signature in black ink, appearing to read 'Kristof Kertesz'.

Kristof Kertesz

TÜV Rheinland InterCert Kft., Product Certification Body — H-1143 Budapest, Gizella út 51-57. — www.tuv.com
Notified Body No. 1008

Validity of certificate can be checked on www.CERTIPEDIA.com