CE 0085

DVGW CERT

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085DN0528
Product Identification No.
Produkt-Identnummer

Field of Application ***Anwendungsbereich***	EU Gas Appliances Regulation (EU/2016/426) *EU-Gasgeräteverordnung (EU/2016/426)*
Distributor ***Vertreiber***	Ferroli Espana S.L.U. C/ Alcalde Martín Cobos nº 4, E-09007 Burgos
Product Category ***Produktart***	Water heaters: Gas instantaneous water heater (1401)
Product Description ***Produktbezeichnung***	Wall-hunging instantaneous water heater with integrated gas burner in modulating operation method and with enclosed combustion chamber
Model ***Modell***	COINTRA CETI ...
Countries of Destination ***Bestimmungsländer***	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports ***Prüfberichte***	type testing: K 3264 2022 T1 from 01.09.2022 (TRG) type testing: K 3264 2022 B2 from 01.09.2022 (TRG)
Test Basis ***Prüfgrundlagen***	EU/2016/426 A III B (09.03.2016) DIN EN 26 (01.08.2015)
Date of Expiry / File No. ***Ablaufdatum / AZ***	01.09.2032 / 22-0362-GEE

70028-04-A-DE

28.10.2022 Kir C-1/2
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DAkkS
Deutsche Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Type ***Typ***	**Technical Data** ***Technische Daten***	**Remarks** ***Bemerkungen***
CETI 12	heat input (Hi): 4,0...23,0 kW	
CETI 15	heat input (Hi): 4,0...29,7 kW	
CETI 17	heat input (Hi): 4,0...33,0 kW	

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

Additionally tested appliance categories, supply pressures and countries of destination:
AL: II2H3B/P, II2R3R; 20 mbar; 30 mbar
AT: II2H3B/P; 20 mbar; 50 mbar
BE: II2E(S)3P, II2E(R)3P; 20/25 mbar; 37 mbar
BG: II2H3B/P, II2R3R; 20 mbar; 30, 37, 50 mbar
CH: II2H3B/P, II2H3P; 20 mbar; 50 mbar
CY: II2H3B/P; 20 mbar; 30 mbar
CZ: II2H3B/P, II2H3P, II2R3R; 20 mbar; 30, 37, 50 mbar
DE: II2E3B/P, II2R3R, II2ELL3B/P; 20 mbar; 50 mbar
DK: II2H3B/P, II2R3R; 20 mbar; 30 mbar
EE: II2H3B/P, II2R3R; 20 mbar; 30 mbar
ES: II2H3P, II2R3R; 20 mbar; 37 mbar
FI: II2H3B/P; 20 mbar; 30 mbar
FR: II2Er3P, II2R3R, II2Esi3P; 20/25 mbar; 37 mbar
GB: II2H3P; 20 mbar; 30 mbar
GR: II2H3B/P, II2R3R, II2H3P; 20 mbar; 37 mbar
HR: II2H3B/P, II2H3P; 20 mbar; 30, 50 mbar
HU: II2H3B/P, II2R3R; 20 mbar; 30, 37, 50 mbar
IE. II2H3P; 20 mbar; 30, 37 mbar
IS: II2H3B/P; 20 mbar; 30 mbar
IT: II2H3B/P, II2HM3B/P, II2R3R, II2H3P; 20 mbar; 30, 37 mbar
LT: II2H3B/P, II2H3P; 20 mbar; 30 mbar
LU: II2H3B/P, II2R3R; 20 mbar; 30, 37, 50 mbar
LV: II2H3B/P, II2R3R; 20 mbar; 30, 37, 50 mbar
NL: II2EK3B/P; 20/25 mbar; 30 mbar
NO: II2H3B/P, II2R3R; 20 mbar; 30 mbar
MT: II2H3B/P, II2R3R; 20 mbar; 30, 37, 50 mbar
MK: II2H3B/P, II2R3R; 20 mbar; 30, 37, 50 mbar
PL: II2ELwLs3B/P, II2E3B/P; 13 mbar; 20 mbar; 30 mbar
PT: II2H3P, II2R3R; 20 mbar; 37 mbar
RO: II2H3B/P, II2H3P; 20 mbar; 30 mbar
SE: II2H3B/P; 20 mbar; 30 mbar
SI: II2H3B/P, II2R3R; 20 mbar; 30 mbar
SK: II2H3B/P; 20 mbar; 30 mbar
TR: II2H3B/P; 20 mbar; 30 mbar

In non-EU countries, the conformity approval will only be accepted once the Gas Appliance Regulation EU/2016/426 will be transferred into national law.
In the UK, the acceptance of CE marking is currently limited to 01 January 2023.