

Declaración de prestaciones DoP 1134-CPR-111

1. Identificación del producto

430048 correspondiente al **GZ DETECTOR HUMO MINI IM128A x1** y código de barras **8430624430488**;

430049 correspondiente al **GZ DETECTOR HUMO MINI IM128A x2** y código de barras **8430624430495**.

2. Uso previsto

Alarmas de humo autónomas

3. Nombre y domicilio del importador

Imprex Europe, S.L.

Avenida de la Industria, 22, Polígono Industrial la Cantueña, CP 28947 Fuenlabrada, Madrid,

CIF N° B-28115764

4. Sistema AVCP

Sistema 1

5. Estándar armonizado

305/2011/EU

EN 14604:2005/AC:2008

Notified body 1134 - ANPI

6. Prestaciones declaradas

Harmonised technical specification		EN 14604: 2005 AC: 2008
Essential Characteristics	Performance 1) 2)	Clause
<i>Nominal activation conditions / sensitivity / Response delay (response time) and performance under fire conditions</i>		
- Smoke alarm signals	<i>pass</i>	4.12
- Inter-connectable smoke alarms	<i>NA</i>	4.18
- Repeatability	<i>pass</i>	5.2
- Directional dependence	<i>pass</i>	5.3
- Initial sensitivity	<i>pass</i>	5.4
- Air movement	<i>pass</i>	5.5
- Dazzling	<i>pass</i>	5.6
- Fire sensitivity	<i>pass</i>	5.15
- Sound output	<i>pass</i>	5.17
- Sounder durability	<i>pass</i>	5.18
- Inter-connectable smoke alarms	<i>NA</i>	5.19
- Alarm silence facility	<i>NA</i>	5.20
<i>Operational reliability</i>		
- Compliance	<i>pass</i>	4.1
- Individual alarm indicator	<i>pass</i>	4.2
- Mains-on indicator	<i>NA</i>	4.3
- Connection of external ancillary devices	<i>NA</i>	4.4
- Means of calibration	<i>NA</i>	4.5
- User replaceable components	<i>pass</i>	4.6
- Normal power source	<i>pass</i>	4.7

