

# COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

## CERTIFICATE Of Conformity

**Certificate No:** 25202303217

**Applicant:** CHAOZHOU HONLI SANITARY WARE TECHNICAL COMPANY LIMITED

**Address of Applicant:** GUWU INDUSTRIAL ZONE, GUXIANG TOWN, CHAOZHOU CITY,  
GUANGDONG PROVINCE, CHINA, 515647

**Product:** Two-piece toilet

**Brand:** /

**Type designation:** See appendix to certificate of conformity

**Technical data:** Pedestal WC pan with integral trap, personal hygiene, Type 1, nominal flush  
volume of 3/5L

The submitted samples of the above product have been tested for CE marking according to the following European Directives:

### (EU)No.305/2011-the Construction Products Regulation

Standard used for showing compliance with the essential requirements in the specified directive:

Standard	Test report	Issued by	Date
EN 997:2018	25202303217	CTC of FOSHAN CUSTOMS	Sep. 19, 2023

The referred test report shows that the product complies with standard recognized as giving presumption of compliance with the essential requirements in the specified EU Directive.

After preparation of the necessary technical documentation as well as the conformity declaration the CE marking as shown below can be affixed on the product. Other relevant Directives have to be observed.

This document is the property of Comprehensive Technology Centre of Foshan Customs, and it is not transferable. Only the applicant may reproduce this certificate.



  
YUAN FANGLI  
Director



Issue Date: Sep.19, 2023  
Expiration Date: Sep.18, 2026

Note: This certificate is part of the full report and should be read in conjunction with it.

COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS  
2/F, Building 18, Lanshi International Metal Exchange Center, Kuiqi Road, Chancheng District, Foshan, Guangdong, China (528000)  
TEL: 86-757-83827991 FAX: 86-757-83827971



COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS

APPENDIX TO  
Certificate of Conformity

*Certificate No:* 25202303217

*Applicant:* CHAOZHOU HONLI SANITARY WARE TECHNICAL COMPANY LIMITED

*Address of Applicant:* GUWU INDUSTRIAL ZONE, GUXIANG TOWN, CHAOZHOU CITY, GUANGDONG PROVINCE, CHINA, 515647

*Product:* Two-piece toilet

*Type designation:* LT-2149A,LT-2175A,LT-2128A,LT-2142A,LT-2196A,LT-2202A,LT-2170A,LT-2171A,  
LT-2180A,LT-2125A,LT-2131A,LT-2093A,LT-2141A,LT-2197A



Note: This certificate is part of the full report and should be read in conjunction with it.

COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS  
2/F, Building 18, Lanshi International Metal Exchange Center, Kuiqi Road, Chancheng District, Foshan, Guangdong, China (528000)  
TEL: 86-757-83827991 FAX: 86-757-83827971



CHAOZHOU HONLI SANITARY WARE  
TECHNICAL COMPANY LIMITED  
GUWU INDUSTRIAL ZONE, GUXIANG TOWN,  
CHAOZHOU CITY, GUANGDONG PROVINCE,  
CHINA, 515647

**23**

LT-2149A

PH

EN 997 — CL 1 – 3/5A



中国认可  
国际互认  
检测  
TESTING  
CNAS L1978



# TEST REPORT

REPORT NO. : 25202303217

SAMPLES: Two-piece toilet

APPLICANT: CHAOZHOU HONLI SANITARY WARE  
TECHNICAL COMPANY LIMITED

DATE OF TEST: 13/09/2023~15/09/2023 (DD/MM/YY)

STATE KEY TESTING LABORATORY OF BUILDING CERAMICS AND SANITARY WARE  
COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN CUSTOMS






# TEST REPORT

Report No.: 25202303217

Page 2 of 4

Name of Sample	Two-piece toilet	Type	WC PAN, PEDESTAL, DUAL FLUSH, Type 1, NOMINAL FLUSH VOLUME OF 3/5L
Mark of Samples	LT-2149A	Description of Samples	The samples are sound, intact and fit for test.
Quantity of Samples	1 Set	Nominal Size	—
Applicant	CHAOZHOU HONLI SANITARY WARE TECHNICAL COMPANY LIMITED	Address of Applicant	GUWU INDUSTRIAL ZONE, GUXIANG TOWN, CHAOZHOU CITY, GUANGDONG PROVINCE, CHINA, 515647
Telephone of Applicant	86-768-6837092	Fax of Applicant	86-768-6837093
Source of Samples	Sample selected by applicant	Received on	05/09/2023
Test Standard	EN 997:2018 <i>WC pans and WC suites with integral trap</i>		
Conclusion of Test	The results conform to the requirements of EN 997: 2018 with respect to the test items.		
Stamp of Test Unit	 Date: 19/09/2023	Address of Test Unit	Address: 2/F, Building 18, Lanshi International Metal Exchange Center, Kuiqi Road, Chancheng District, Foshan, Guangdong, China (528000) Tel: 86-757-83960558 86-757-83827991 E-mail: fsiqtc@163.com
Notes	<ol style="list-style-type: none"> <li>1. All inspections are carried out conscientiously to the best of our knowledge and ability. This report does not in any respect absolve the other related parties from his contractual and legal obligations.</li> <li>2. This report shall not be reproduced, except in full, without the prior written approval from the issuing laboratory.</li> <li>3. The results in this report apply to the samples only.</li> <li>4. The sample information are declared by applicant, and laboratory is not responsible for the authenticity.</li> </ol>		
Possible test case verdicts	<ol style="list-style-type: none"> <li>1. P(ass) : test item does meet the requirement.</li> <li>2. N/A : test case does not apply to the test item.</li> <li>3. F(ail) : test item does not meet the requirement.</li> <li>4. —: verdict/test was not carried out.</li> </ol>		

Tested by

Inspected by

Approved by

## TEST REPORT

Report No.: 25202303217

Page 3 of 4

### Remark of applicant

The test report data was based on item No. LT-2149A, in a family of two-piece toilet. All items in the family are same in water absorption, material, method of manufacture and finish surface characteristics, except for the design of appearance.

#### Items in the family:

LT-2149A,LT-2175A,LT-2128A,LT-2142A,LT-2196A,LT-2202A,LT-2170A,LT-2171A,LT-2180A,LT-2125A,LT-2131A,LT-2093A,LT-2141A,LT-2197A

Manufacturer: CHAOZHOU HONLI SANITARY WARE TECHNICAL COMPANY LIMITED

Address of Manufacturer: GUWU INDUSTRIAL ZONE, GUXIANG TOWN, CHAOZHOU CITY, GUANGDONG PROVINCE, CHINA, 515647

### Photo of Samples



LT-2149A



# TEST REPORT

Report No.: 25202303217

Page 4 of 4

EN 997:2018 WC pans and WC suites with integral trap				
Clause	Characteristics	Requirements	Results	Verdicts
5.1	Depth of water seal	$\geq 50$ mm	55mm	Pass
5.2	Flushing requirements			
	Wash of bowl	The arithmetic average of any unflushed area below the rim and above the surface of the water in the trap shall not be more than 50 cm <sup>2</sup> after five flushing operations.	No sawdust remaining	Pass
	Flushing of toilet paper	12 sheets of toilet paper shall be flushed out of the WC pan a minimum of 4 times out of five tests.	Compliant	Pass
	Flushing of fifty small plastic balls	Each with 50 balls, a minimum of 85% of the balls shall be flushed out of the WC pan.	—	N/A
	Oversplashing	Flushing water shall not splash beyond the rim of the bowl and wet the floor. Only a few small drops are permissible.	Compliant	pass
	After-flush volume	An after-flush volume of 2.5L or 2.8L as appropriate is required.	3.2L~3.6L	pass
5.3	Water absorption	Average: $E \leq 0.5\%$	Average: 0.08%	Pass
5.4	Static load	Wall-hung and non-ceramic WC pans and suites shall withstand a force of $(4.00 \pm 0.05)$ kN without showing any evidence of cracking or permanent deformation.	—	N/A
5.5	Additional characteristics of flushing cisterns for close-coupled suites and one-piece WCs			
5.5.4	Flush volume(s) of the flushing cistern	4.5L~5.4L	5.2L	Pass
	Reduced flush volume	Maximum 2/3 of the nominal flush volume as specified by the manufacturer.	3.1L	Pass

\*\*\* \*\*

End of Test Report