

Declaración de prestaciones DoP 1008-TUV-HU23HQXF 001

1. Identificación del producto

430087C correspondiente al **GZ DETECTOR HUMO MINI BAST IM170** y código de barras **8430624300873**

2. Uso previsto

Alarmas de humo autónomas

3. Nombre y dirección del importador

Imprex Europe, S.L.

Avenida de la Industria, 22, Polígono Industrial la Cantueña, CP 28947 Fuenlabrada, Madrid,
CIF Nº B-28115764

4. Sistema AVCP

Sistema 1

5. Estándar armonizado

305/2011/EU

EN 14604:2005/AC:2008

Notified body 1008 - TUV

6. Prestaciones declaradas

Essential characteristics	Performance	Harmonised technical specification
Operational reliability	Pass	EN 14604: 2005 EN 14604: 2005/AC:2008
Repeatability	Pass	
Directional dependence	Pass	
Initial sensitivity	Pass	
Air movement	Pass	
Dazzling (45°, 90°)	Pass	
Dry heat (55±2°C, 2h)	Pass	
Cold (operational) (0±2°C, 2h)	Pass	
Damp heat (operational) (40±2°C, 93±3%, 96h)	Pass	
Sulphur dioxide (SO2) corrosion (25 °C; 93 %; 25 ppm; 4 days)	Pass	
Impact (1,9±0,1 J; 1 time)	Pass	
Vibration (operational) (10 to 150 Hz; 5m/s ² ; 3 axes)	Pass	
Vibration (endurance) (10 to 150 Hz; 10m/s ² ; 3 axes)	Pass	
Electromagnetic Compatibility (EMC), Immunity tests (operational)	Pass	
Fire sensitivity (TF2; TF3; TF4; TF5)	Pass	

